

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. - 394

Dated:- 10/03/2026

It is certified that an inspection team headed by Amar Kumar Assistant

Engineer P.H. Subdivision Araria (Name of the Officer with designation)

from P.H. Division Araria PHED inspected the
AARYA MISSION SCHOOL MANIKPUR NH-57, BARDAHA ARARIA (Name &

Address of the School) on 09/3/2026 (Date of inspection) and on the basis of
Water Test Report (Attached) bearing no. 393 dated 10/03/2026

of DISTRICT LEVEL WATER TESTING LAB ARARIA (PHED Lab) Certified that

the AARYA MISSION SCHOOL MANIKPUR NH-57, BARDAHA ARARIA (Name of the School) has

safe drinking water facilities for the students and members of staff of the institution.

School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid till ONE YEAR

Signature with Seal Assistant Engineer..

Name: - AMAR P.H. Subdivision Araria (West)

Designation: ASSISTANT ENGINEER

Name & Address of the Office/Department:



To

AARYA MISSION SCHOOL

MANIKPUR, N.H.-57, BARDAHA, ARARIA

(Name & Address of the Institution)

Note: The Certificate is to be issued by authorized officer / PHED Lab / Local Bodies

Manager
Arya Mission School
NH-57, Manikpur Bardaha
Araria-854311

V. Singh
Principal
Arya Mission School (10+2)
Aff. No.- 330850, Code-65847

Letter No: 393

Date:10/03/2026

Government of Bihar**DISTRICT LEVEL WATER TESTING LABORATORY UNDER, PUBLIC HEALTH DIVISION ARARIA.****CHEMICAL AND BACTERIOLOGICAL REPORT OF DRINKING WATER SAMPLES**

District Name:- Araria

Sample Collected By- Jeevan Kumar

Testing Date:-10-03-2026

SL. No.	Location of Source	Parameters Examined(Test Result in ppm)													
		pH	TDS	Conductivity	Turbidity	Total Hardness	Calcium	Magnesium	Chloride	Total Alkalinity	Iron	Nitrate	Fluoride	Arsenic	Bacteria
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
1	AARYA MISSION SCHOOOL, MANIKPUR,NH- 57, BARDAHA, ARARIA	7.41	178	273	1.2	141	35	14	42	152	0.43	BDL	-	-	-
BIS 10500:2012 (second revision)	Desireable Limit	6.5-8.5	500	-	1.0	200	75	30	250	200	1.0	45	1.0	0.01	-Ve
	Permissible Limit in absence of alternate source	NR	2000	-	5.0	600	200	100	1000	600	NR	NR	1.5	NR	**

Note (i) BDL means below detection Limit (ii) NR means no relaxation

10/03/2026
 Chemist (Research Assistant)
 Research Assistant (Chemist)
 P.H. Division Araria
 District Laboratory
 P.H. Division, Araria

Manager
 Arya Mission School
 NH-57, Manikpur Bardaha
 Araria-854311

Principal
 Arya Mission School (10+2)
 Aff. No.- 330050, Code-65847